

1 2 3 4 5 Draft Regional Transmission Plan for the 2020- 2021 NorthernGrid Planning Cycle 7 NorthernGrid Member Planning Committee Approval Date: tbd



9 Executive Summary

The NorthernGrid 2020-2021 Regional Transmission Plan was developed per the Study Scope that
 outlines the NorthernGrid 2020-2021 regional planning process, as required under FERC Orders No.
 890 and 1000, in accordance with each Enrolled Party's Open Access Tariff (OATT) Attachment K –
 Regional Planning Process and Northern Grid Planning Agreement, and the results are presented in
 this report. The objective of the planning process is to identify the projects that more cost
 effectively or efficiently meet the needs of the NorthernGrid members in a 10-year future.

16 The process started with a summary of transmission needs from each of the Members. For a 10-17 year future, each Member submitted their forecasted load, expected resource additions or 18 retirements, and expected transmission topology. All this information was then assimilated into the 19 2030 WECC Anchor Data Set (ADS). From that base case, a production cost model analysis was 20 performed to identify the stress conditions of interest for the NorthernGrid footprint. The stress 21 conditions were selected to represent typical or expected operating conditions for the NorthernGrid 22 footprint. The NorthernGrid footprint spans a wide geographic area; because of this, heavy 23 conditions for both summer and winter were selected. There is enough proposed wind generation 24 in Wyoming to have a potential impact on the reliability of the NorthernGrid footprint; because of 25 this, an hour representing high output from Wyoming wind resources was selected. Needs were 26 also identified across southern Idaho, so a high Idaho to Northwest (west to east) case and Borah West (east to west) case were developed. Altogether, eight stress conditions for the NorthernGrid 27 28 footprint were identified.

The results of the contingency analyses from those eight respective base cases formed the
 foundation for the selection of projects in the Regional Transmission Plan. Contingencies were
 submitted by the Members and focused on 230 kV and above electrical facilities. The NorthernGrid
 footprint along with adjacent neighboring regions were monitored.

The base cases contained all planned regional member projects. To identify the set of projects for the Regional Transmission Plan, portions of the planned regional projects were removed from the base cases to ascertain if a subset of the proposed regional projects would meet the needs of the transmission system more cost effectively than the entire set.

Consideration was also given to the interregional and non-incumbent regional projects that were submitted. The interregional projects and non-incumbent regional projects were first analyzed to determine if, without the addition of the proposed regional projects, they would meet the needs of the NorthernGrid footprint reliably. Further scrutiny was given to the interregional and nonincumbent regional projects to analyze their interplay with select regional projects if the

42 interregional or non-incumbent regional project alone resulted in reliability violations.

Three developers, TransCanyon LLC, Great Basin Transmission, LLC, and PowerBridge met the
 criteria to be classified as Qualified Developers for this planning cycle. Ultimately, cost allocation
 analysis was not required as none of the interregional or non-incumbent regional projects were
 selected into the Regional Transmission Plan.





48 Figure 1: Regional Transmission Plan, regional combination {03}

- 49 Figure 1 above provides a simplistic depiction of the regional projects that make up the Regional
- 50 Transmission Plan. The Regional Transmission Plan projects were determined to be the most cost-
- 51 effective solution to the NorthernGrid region given the parameters that were analyzed. The upgrades
- 52 through the Cedar Hill bus increase the capacity of the transmission system between Populus and
- 53 Hemingway. None of the interregional or non-incumbent projects met the needs of the region.

54 Table of Contents

55 Contents

56	Executive Summary	. 2
57	Table of Contents	.3
58	Regional Planning Development	.4
59	NorthernGrid Overview	.4
60	Study Process	.5
61	Study Scope	.5
62	Study Methodology and Criteria	.5
63	Loads and Resources	.6
64	Base Case Development	.6
65	Contingencies and Criteria	.8
66	Selection of Projects	.8
67	Regional Projects	11

NorthernGrid

68	Interregional Projects	12
69	Non-Incumbent Projects	13
70	Analysis Results	14
71	Regional Combinations	15
72	Interregional and Non-Incumbent Regional	17
73	Interregional Coordination Process	19
74	Cost Allocation	19
75	Regional Transmission Plan	20
76	Appendix A: Definitions and Terms	20
77	Appendix B: Study Scope	21
78	Appendix C: Rankings	23
79	Appendix D: Complete list of all RC combos	24
80	Appendix E: Visual Aides for the Regional Combinations	25
81		

82 Regional Planning Development

The Regional Transmission Plan is the result of the work performed as outlined in the study scope for 83 84 the NorthernGrid 2020-2021 regional transmission planning process. Regional Planning is required 85 under FERC Orders No. 890 and 1000 and was executed in accordance with each Enrolled Party's Open 86 Access Tariff (OATT) Attachment K – Regional Planning Process and NorthernGrid Planning Agreement. 87 The production of a Regional Transmission Plan satisfies FERC Order 1000 requirements for each region 88 to produce a plan. To develop the Plan, the NorthernGrid members established the Baseline Projects 89 which were then evaluated for inclusion in the final Regional Transmission Plan. NorthernGrid used 90 steady state analysis to assess which projects could best meet system reliability performance 91 requirements and transmission needs for the NorthernGrid footprint in a 10-year future. Enrolled Parties 92 submitted updated Load and Resource information which was incorporated into the study effort. There 93 were no Material Adverse Impacts noted for any of the solutions considered.

94

95 NorthernGrid Overview

- 96 The NorthernGrid is comprised of Avista (AVA), Bonneville Power Administration (BPA), Chelan PUD
- 97 (CHPD), Grant County PUD (GCPD), Idaho Power Company (IPC), Berkshire Hathaway Energy (BHE,
- 98 formerly Montana Alberta Tie Line, MATL), NorthWestern Energy (NWMT), PacifiCorp East and West
- 99 (PACE and PACW), Portland General Electric (PGE), Puget Sound Energy (PSE), Seattle City Light (SCL),
- 100 Snohomish PUD (SNPD), Tacoma Power (TPWR). The member Balancing Authority Areas are illustrated
- 101 in Figure 2 below.





103 Figure 2: NorthernGrid footprint

104 Figure 2 shows the NorthernGrid footprint. For the purposes of the regional transmission plan data

analysis and study case development, the NorthernGrid MPC divided the study area into the Pacific

- 106 Northwest (NG-PNW) and Intermountain states (NG-IM) areas as shown by the brown line in Figure 2
- 107 above.

102

108 Study Process

109 Study Scope

- The objective of the transmission planning study is to produce the NorthernGrid Regional Transmission
 Plan, through the evaluation and selection of regional and interregional projects that effectively satisfies
 all the transmission needs within the NorthernGrid region. The regional needs were sourced from
 member data submissions, including load forecasts, resource additions and retirements, projected
- transmission, and public policy requirements. The Study Scope in its entirety is provided in Appendix B:
- 115 Study Scope.

116 Study Methodology and Criteria

- 117 To assess the 2030 loads and resources anticipated for the NorthernGrid footprint, a combination of
- 118 power flow and production cost model techniques were used. A Western Electricity Coordinating
- 119 Council (WECC) base case was then put through a production cost modeling effort to identify stressed
- 120 conditions on the NorthernGrid footprint based on the economic dispatch of planned resources. The
- 121 stressed conditions were translated into base cases which became the basis for the analysis effort. The
- selected base cases were run through a contingency analysis using member-supplied contingencies. All



- 123 contingencies were categorized per the North American Electric Reliability Corporation (NERC)
- 124 transmission planning criteria document, "TPL 001-04". The NorthernGrid footprint as well as
- 125 immediate neighboring regions were monitored. The analysis of the contingency results accounted for
- 126 any area-specific Member Committee criteria, otherwise, NERC TPL 001-04 criteria was used.
- 127 Loads and Resources
- 128 Members submitted Loads and Resources data along with their current transmission plans in the first
- 129 quarter; this data was consolidated and used to develop the Study Scope. The needs of the
- 130 NorthernGrid footprint were identified through these submittals. No Loads and Resources data updates
- 131 were submitted in the fifth quarter. All loads and resources characteristics are captured in the Study
- 132 Scope which is available in Appendix B: Study Scope.

133 Base Case Development

134 The WECC 2030 Anchor Data Set seed case was used as the starting point to produce the base cases

- used in the reliability analysis. The Anchor Data Set seed case was put through a production cost
- 136 modeling effort to identify the stress conditions of interest for the NorthernGrid footprint from 8760
- 137 potential hourly conditions. These operating conditions were created through modeling the economic
- dispatch of the resources combined with the expected loading conditions for the time of year and
- 139 creating base cases for each of the 8760 hours in a year. These models account for seasonal variations
- in load and resource availability. For example, base cases representing a spring condition will reflect
- 141 more availability of hydro generation than do the base cases that represent a fall condition. The
- 142 NorthernGrid Planning Committee discussed the stress conditions of interest and ultimately selected 143 eight hours to model and study the regional transmission system. These eight hours, representing eight
- eight hours to model and study the regional transmission system. These eight hours, representing eightdispatch system conditions, were selected to represent known or expected operating conditions for the
- 145 NorthernGrid footprint and are identified in Table 1. Members reviewed these cases and provided
- additional tuning and adjustments as appropriate for each scenario.
- 147 The hours were selected for known or expected "stresses" on the NorthernGrid footprint. The
- 148 NorthernGrid footprint spans a wide geographic area; because of this, heavy conditions for both
- summer and winter were selected. There is enough proposed wind generation in Wyoming to have a
- 150 potential impact on the reliability of the NorthernGrid footprint; because of this, an hour representing
- 151 high output from Wyoming wind resources was selected. Needs were also identified across southern
- 152 Idaho, so a high Idaho to Northwest (west to east) case and Borah West (east to west) case were
- developed. The NorthernGrid Planning Committee voted on, and approved, the study hours identified in
- 154
- 155
- 156
- 157
- 158
- 159



160 Table 1: Base Case Stress Conditions

Condition	Date	Hour Ending	NorthernGrid Load (MW)	NorthernGrid Generation (MW)
NorthernGrid region summer peak load	July 30	16:00		
NorthernGrid region winter peak load	December 10	<mark>19:0</mark> 0		
High Wyoming Wind	February 1	1:00		
High Idaho to Northwest path [west to east]	July 20	17:00		
High Borah West path [east to west]	September 29	1:00		
High COI path [south to north]	March 10	15:00		
High West of Cascades paths [east to west]	April 3	11:00		
High COI and PDCI paths with high hydro	June 4	18:00		



161

162 Figure 3: Paths of interest to the NorthernGrid footprint

163 Figure 3 above allows for identification of the four WECC paths of most interest to the NorthernGrid

164 footprint for purposes of stressing the transmission system. Not all WECC paths relating to

165 NorthernGrid are displayed. The California-Oregon Intertie (COI) is needed for inter-regional transfers

166 between the California Independent System Operator (CAISO) and NorthernGrid. West of Cascades,



167 Idaho to the Northwest, and Borah West are all crucial to the reliability of the NorthernGrid footprintand stresses may occur in both directions.

169 Contingencies and Criteria

170 Contingency analysis is the modeling of systematically removing specified pieces of equipment from

- 171 service and measuring the resulting impact to the transmission system. Thermal overloads occur when
- the electrons flowing through a piece of equipment exceed the capability of the equipment which
- 173 causes heat to build up; excess heat occurs which can then damage the equipment. Typically, a thermal
- overload results from the loss of a transmission line or transformer, not necessarily from the loss of
- 175 voltage control elements such as capacitor or reactor banks. Voltage excursions occur when the 176 reactive support of the transmission system changes, as can happen during the loss of a piece of
- equipment. Voltage excursions can be high or low, either of which causes undue stress on the
- equipment experiencing the excursion. Due to the interplay of all the pieces of equipment in a
- transmission system, the loss of any piece of equipment has the potential to cause a voltage excursion
- 180 on the transmission system.
- 181 NorthernGrid Members submitted regionally significant contingencies used in the analysis for the
- 182 development of the Plan. Contingencies on major WECC Paths relevant to the NorthernGrid footprint as
- 183 well as contingencies on pieces of equipment in the 200 kV and above voltage classes were the primary
- 184 focus. These regionally significant contingencies were selected for their criticality to the NorthernGrid
- 185 footprint. The contingencies were categorized using Table 1 from NERC TPL-001-4. The post-
- 186 contingency system analysis was performed using applicable NERC and WECC criteria while accounting
- 187 for any member provided thermal or voltage criteria.
- 188 The NorthernGrid footprint as well as neighboring regions were monitored during the contingency
- analysis to determine if any negative impacts occur to the reliability of the transmission system due to
- 190 the introduction of the regional projects. If negative impacts to the transmission system of neighboring
- 191 regions could not be mitigated through operational changes for any regional combination, coordination
- 192 would have to occur to identify the appropriate mitigation and the costs of that mitigation would be
- added to the cost of the regional project. No negative contingency results were observed in the
- 194 neighboring regions and as such no Material Adverse Impacts were identified for any of the
- 195 combinations considered.

196 Selection of Projects

- 197 The objective of the regional transmission analysis is to identify a set of transmission projects that cost-
- 198 effectively meets the transmission service and reliability needs of the NorthernGrid footprint ten years
- in the future. To accomplish this goal, NorthernGrid started with base cases that include member
- 200 planned future regional projects modeled as "in-service", as displayed below in Figure 4. Collectively,
- 201 these regional projects comprise the Baseline Member Projects, or the "BLMP". Sensitivity cases based
- 202 on combinations of various regional project components being systematically removed from the BLMP
- 203 cases created a set of Regional Combination cases to test against the performance of the BLMP cases.
- 204 While the BLMP includes the highest number of regional projects, the analysis will evaluate whether a



- 205 subset of the BLMP may cost-effectively meet the needs of the NorthernGrid footprint while
- 206 maintaining system reliability.



207 208

209

Figure 4 and Table 2 provide a visual demonstration of the BLMP. None of the interregional or nonincumbent projects are selected in the BLMP. This figure is not demonstrative of the entire set of
upgrades associated with any main portion of the regional combinations, rather it is intended to help

the reader understand in general the topology of interest. Boardman 525 kV is listed as the terminating

- point of the Boardman to Hemingway project to help preserve continuity with the naming convention;
- in actuality, the project terminates at Longhorn. Visual Aides for all the regional combinations can be
- found in Appendix E. Table C.1 in Appendix C of the Study Scope lists all the combinations considered.

218 Given the large number of possible regional combinations that can be created from subsets of the

- 219 BLMP, the members selected those regional combinations that were collectively determined as being of
- interest to the region. The BLMP gets naturally grouped into projects by their geographic locations.
- 221 From west to east, the groupings are as follows:
- 222 1. Longhorn to Hemingway
- This project is often referred to as "B2H" as Boardman was the original terminus. This project now terminates at Longhorn.
- 225 2. Hemingway to Populus



- There are two configurations of the Gateway West projects that form natural subsets of the
 Gateway projects: Hemingway to Cedar Hill to Populus and Hemingway to Midpoint to Borah to
 Populus.
- 229 3. Populus to Anticline to Aeolus
- 230 Anticline to Aeolus is online and only added here for continuity.
- 231 4. Aeolus to Clover (Gateway South)
- 232 The regional combinations can be thought of as being built from the "inside out" from a regional
- 233 combination perspective. Both main configurations of the Hemingway to Populus segment are tested,
- with the Hemingway to Cedar Hill segment including consideration of Midpoint to Cedar Hill. All the
- other natural groupings are then tested against the three main paths through Hemingway to Populus.
- After the contingencies were run, the raw counts of violations were ranked using weighting criteria
- 237 developed by the NorthernGrid Member Planning Committee. The rankings give less weight to those
- contingency categories that either have system adjustments available, can be addressed locally such
- as reconfiguring a station to avoid a breaker failure issue, or have been determined to be less likely to
- 240 occur. The results were further ranked by voltage class and severity of the violation; Appendix C:
- 241 Rankings lists the full complement of ranking factors used.
- 242 The ranked violations for the BLMP and Regional Combination project combinations were presented and
- summarized using Excel Pivot Table features and charts. The selection of the regional projects in the
- Plan is determined by the combination of projects that results in a transmission system with a weighted
- reliability score that exceeds the reliability performance of the other combinations and offers a cost-
- 246 effective solution for members.



247 Regional Projects



248

249 Figure 5: NorthernGrid footprint with regional project overlay

250 Antelope to Goshen 345 kV Transmission Line

- 251 The transmission facilities submitted to NorthernGrid for modeling the UAMPS generation addition near
- 252 Antelope substation are preliminary in nature as detailed technical studies have not been completed.
- 253 One of the keys assumptions to the single 345 kV line addition between Antelope and Goshen is that
- 254 UAMPS has indicated that the proposed generation can be tripped for outage of the Antelope Goshen
- 255 345 kV line.

256 Boardman to Hemingway Transmission Line Project (B2H)

- 257 Boardman to Hemingway 500 kV line, Hemingway to Bowmont and Bowmont to Hubbard 230 kV lines.
- 258 This includes two sections of series compensation. The Oregon end of the line was terminated at the
- 259 Longhorn station, which is near the town of Boardman, Oregon.
- 260 Gateway South Transmission Project



- 261 Aeolus to Clover 500 kV Line. Based on guidance from PacifiCorp, the Windstar-Shirley Basin 230 kV line
- 262 (part of Gateway West) was treated as part of the Aeolus-Clover project.

263 Gateway West Transmission Project

- A suite of four project segments were evaluated for Gateway West. These were:
- 265 1. Populus-Cedar Hills-Hemingway 500 kV
 - 2. Populas-Borah-Midpoint-Hemingway 500 kV
- 267 3. Midpoint-Cedar Hills 500 kV
 - 4. Anticline-Populus 500 kV
- 269

271

268

266

270 Interregional Projects and Non-Incumbent Regional



- 272 Figure 6: Interregional and Non-Incumbent Regional Projects
- 273 Cross-Tie Transmission Project
- 274 Interregional Evaluation Plan: https://www.northerngrid.net/resources/cross-tie-itp-evaluation-plan-2020-21
- 275 TransCanyon LLC is proposing the Cross-Tie Project, a 1,500 MW, 500 kV single circuit transmission
- 276 project that will be constructed between central Utah and east-central Nevada. The project connects
- 277 PacifiCorp's planned 500-kV Clover substation (in the NorthernGrid planning region) with NV Energy's
- existing 500 kV Robinson Summit substation (in the WestConnect planning region).
- 279 Cross-Tie has proposed 9,891 MW of total cumulative resource additions (3,567 MW Solar, 3,914 MW
- 280 Wind, and 3,410 MW Natural Gas) as a result of the proposed transmission line. These resources are



- located in the states of Wyoming and Utah. Please see the appendix for a data table of proposed
- 282 generation associated with the Cross-Tie project.

283 Southwest Intertie Project North (SWIP)

- 284 Interregional Evaluation Plan: https://www.northerngrid.net/resources/swip-north-itp-evaluation-plan
- 285 Great Basin Transmission, LLC ("GBT"), an affiliate of LS Power, submitted the 275-mile northern portion
- of the Southwest Intertie Project (SWIP) to the California ISO and NorthernGrid. SWIP-North was also
- submitted into WestConnect's planning process by the Western Energy Connection (WEC), LLC, a
- 288 subsidiary of LS Power. The SWIP-North Project connects the Midpoint 500 kV substation (in
- 289 NorthernGrid) to the Robinson Summit 500 kV substation (in WestConnect) with a 500-kV single circuit
- AC transmission line. The SWIP is expected to have a bi-directional WECC-approved path rating of
- approximately 2000 MW.
- 292 SWIP North has proposed 1,850 MW of new wind generation resources located in Idaho as a result of
- 293 the transmission line. Please see the appendix for a data table of proposed generation associated with
- the SWIP North project.

295 TransWest Express

- 296 Interregional Evaluation Plan: <u>https://www.northerngrid.net/resources/transwest-express-itp-evaluation-plan</u>
- 297 TransWest Express is a 500 kV DC and 500 kV AC transmission project proposed by TransWest. The
- 298 TransWest Express (TWE) Transmission Project consists of three discrete interconnected transmission
- 299 segments that, when considered together, will interconnect transmission infrastructure in Wyoming,
- 300 Utah, and southern Nevada. TransWest has submitted each of the following TWE Project segments as
- 301 separate ITP submittals:
- A 405-mile, bi-directional 3,000 MW, ±500 kV, high voltage direct current (HVDC) transmission system
 with terminals in south-central Wyoming and central Utah (the WY-IPP DC Project).
- A 278-mile 1,500 MW 500 kV alternating current (AC) transmission line with terminals in central Utah
 and southeastern Nevada (the IPP-Crystal 500 kV AC Project.
- 306 A 50-mile, 1,680 MW 500 kV AC transmission line with terminals in southeastern Nevada, and
- 307 southwestern Nevada (the Crystal-Eldorado 500 kV AC Project).
- 308 Transwest Express has proposed 3,310 MW of wind generation as a result of the transmission line.
- Please see the appendix for a data table of proposed generation associated with the transmissionproject.
- 311 Non-Incumbent Projects

312 Cascade Renewable Transmission System

- PowerBridge is proposing to construct the Cascade Renewable Transmission System Project. This Project
- is an 80-mile, 1,100 MW transfer capacity +/- 400 kV HVDC underground cable (95 percent installed
- underwater) interconnecting with the grid through two +/- 1100 MW AC/DC converter stations



- interconnecting with the AC grid at Big Eddy and Harborton substation. There is no proposed generation
- 317 resource associated with the transmission line.

318 Loco Falls Greenline

- Absaroka is proposing a merchant transmission project connecting Great Falls 230 kV substation to the
- 320 Colstrip 500 kV Transmission System. The project consists of two 230 kV transmission circuits and a new
- 321 Loco Mountain Substation with 230 to 500 kV transformation. There are no proposed generation
- 322 resources associated with the transmission line.

323 Analysis Results

- 324 Once the base cases were created to reflect the topology and loading conditions of interest, they were
- run through contingency analysis. When running contingency analyses, both the cause of the
- 326 contingency and the impact of the contingency are vital to ascertaining the reliability of the transmission
- 327 system. The cause and the impact are considered in conjunction with the voltage class of the
- 328 equipment. In general, losses of higher voltage equipment have more of an impact on the transmission
- 329 system than do the losses of lower voltage equipment. Altogether, the ranking factor for each of the
- three categories: voltage class, cause of the contingency, impact of the contingency was multiplied to
- 331 produce an overall Ranking, an example is provided in Appendix C: Rankings.



332 Base Cases

333

334 Figure 7: Ranked contingency results for the eight BLMP cases



- 335 *Figure 7* displays the ranked contingency violations for the eight base cases developed to represent the
- different stress conditions of interest. All eight base cases are derived from the BLMP and their only
- 337 differences stem from the varying load and resource combinations that resulted from the production
- 338 cost model analysis. Thermal excursions identify the portions of the system that may need
- 339 infrastructure improvement to support the movement of electrons whereas voltage changes identify the
- 340 portions of the transmission system that may need reactive equipment to support the overall voltage.
- 341 By emphasizing the change in volts, either high or low, the analysis effort is well situated to identify
- those contingencies that led to changes in the transmission system and to put less emphasis on voltage
- 343 excursions that may be present in the BLMP due to the PCM process.



344 Regional Combinations

Figure 8 above displays the ranked contingency results for the regional combinations of projects. The
 BLMP case represents the case that has all the regional projects modeled as "in-service". The rest of the
 combinations are composed of a subset of the entire set of possible regional projects. A few notable

350 observations:

- The BLMP case has fewer violations than most of the other regional combinations. This result is
 expected as the BLMP case has the largest number of transmission upgrades compared to the
 regional combinations.
- Regional combinations {03, 04, 05} form a natural group and result in the fewest ranked
 violations. These three regional combinations all have the Boardman to Hemingway, Gateway
 South, and the Anticline to Populus branch of the Gateway West projects.
- 357 3. The only difference between regional combinations {03} and {04} is the presence of Midpoint to
 358 Cedar Hill.
- Regional combination {24} has no upgrades between Populus and Midpoint but does have the
 addition of the SWIP North project. Regional combination was analyzed with and without
 Gateway South and it was found that with Gateway South yielded a more reliable system.

³⁴⁶ Figure 8: Ranked contingency results, all regional combinations with all cases



- Regional combinations {06, 07, 08} are a subset of regional combinations {03, 04, 05} in that they do not have the Gateway South project and they yield a larger number of violations.
 Regional combinations {10, 11, 12} are a subset of regional combinations {03, 04, 05} in that they do not have the Boardman to Hemingway project and they yield a larger number of violations.
 Regional combinations {17, 21, 27} have results similar to those of regional combinations {10, 11, 12}. Of the three regional combinations, {17, 21, 27}, regional combination {17} is the only one that does not have the Boardman to Hemingway project.
- 369
- 370 Not all regional combinations are applicable to all base cases. Appendix D: Complete list of all RC
- combos lists which stress conditions are to be considered for each of the regional combinations. The
- best performing regional combinations {03, 04, 05, 10, 11, 12, 21, 23, 27} all have the same three stress
- 373 conditions: Wyoming wind, Idaho to the Northwest, Borah-West. Additionally, regional combinations
- 374 {03, 04, 05, 10, 11, 12} have the following two stress conditions: Heavy Summer and COI South to North.
- 375 Consistent with the conclusions from all eight base cases, regional combinations {03, 04, 05} result in the
- 376 fewest ranked contingency violations with regional combination {27} having the next fewest.
- 377 *Figure 9* shows the details of the contingency analysis for regional combinations {03, 04, 05, 27}.



Figure 9: Ranked contingency results for regional combinations {03, 04, 06, 27} with 5 base case conditions

380 There is negligable difference in the performace of regional combinations {03} and {04}; regional

381 combination {03} has fewer pieces of equipment to install than regional combination {04} and for that

reason, regional combination {03} will be given preference.



- Figure 10below shows regional combination {03} and Figure XXXX shows regional combination {05}.
- 384 These figures do not detail the entire transmission system between Boardman and Clover, rather, they
- 385 are intended to visually depict the segments under consideration that yield the fewest reliability
- 386 violations for the NorthernGrid footprint.

388



389 Figure 10: Regional Projects **{03}** and **{05**}

390 Figure 10 depicts major segments of the regional projects and does not constitute their entirety. Red

391 segments belong to regional combination {03}, blue segments belong to regional combionation {05}, and

392 purple segments belong to both. As can be seen in XXXX not all the portions of the Gateway West

393 project are needed to support the reliability of the NorthernGrid footprint. Electrons flowing between

Populus and Hemingway need only one path; either south through Cedar Hill or north through Borah.

- 395 The Cedar Hill route increases the capacity on the transmission system between Populus and
- 396 Hemingway. The segments associated with the Cedar Hill substation are new whereas the segments
- associated with Midpoint and Borah are upgrading existing facilities. The main contingency for the
- 398 Midpoint-Borah segments is the loss of the line that is getting upgraded, which does not increase the
- 399 capacity of the system from a contingency perspective. The Cedar Hill facilities provide an alternate
- 400 route for electrons to flow, which increases the capacity of the system. Conservative estimates suggest
- 401 that upwards of 1500 MW can be gained in capacity for the Cedar Hill facilities.
- 402 Interregional and Non-Incumbent Regional

403 Three interregional and two non-incumbent regional projects were then analyzed to see if alone,

- without the presence of the regional projects, any of the interregional or the non-incumbent projectswould meet the needs of the NorthernGrid region.
- There were no voltage excursions that were introduced by any of the projects in Figure 11 which is why only thermal violations are displayed. There are significantly more thermal overloads in the cases that



408 have only an interregional or non-incumbent regional project than the case that has the full

409 complement of regional projects.



411 Figure 11: Interregional or non-incumbent regional project with no regional upgrades

Odd-numbered regional combinations {29, 31, 33, 35, 37, 39} were developed based off the stand-alone
 analyses and Appendix D: Complete list of all RC combos provides the final list of combinations.

414 1. Regional combinations {03, 04, 05} yield the fewest violations.

- 4152. The interregional and non-incumbent projects start at RC{28}; there are significantly more416violations in regional combinations {28+} than in regional combinations {03, 04, 05}.
- 417

410

418 At this point, the analysis suggests that either interregional or non-incumbent projects by themselves, in

the absence of any regional upgrades, are insufficient to meet the needs of the NorthernGrid footprint.





421 Figure 12: Ranked continency results for select combinations

422 Figure 12 above shows the entire set of results for the majority of the combinations considered.

- 423 Starting with regional combination {28} are those combinations that take interregional projects into
- 424 consideration.

420

- Regional combinations {03, 04, 05} as well as {33_03, 33_05} all appear to have the fewest violations. Regional combination {33_03} is simply regional combination {03} with the addition of the Loco Falls project. The Loco Falls project alone is insufficient to meet the needs of the region. Loco Falls in conjunction with regional combination {03} performs well but would be more expensive to build than just regional combination {03} by itself.
- 430 2. Interregional projects by themselves, without the addition of regional projects, are insufficient431 to meet the needs of the NorthernGrid region as they lead to significantly more violations.

432 Interregional Coordination Process

433 NorthernGrid met with WestConnect and CAISO to coordinate base cases, assumptions, and

methodologies at the Annual Interregional Information Exchange. None of the interregional projectswere selected into regional Plans for the neighboring regions.

436 Cost Allocation

437 The interregional projects submitted for consideration in the NorthernGrid footprint were not selected

- 438 into the Plans of the other regions. For this cycle, there are no projects that meet the criteria for cost
- allocation. The Study scope in Appendix B: Study Scope provides the complete list of developers who
- 440 pre-qualified through the Northern Tier Transmission Group 2018-2019 planning process.



441 Regional Transmission Plan



- 443 Figure 13: The Regional Transmission Plan for the 2020-2021 NorthernGrid cycle
- 444 Regional combination {03} forms the basis of the Regional Transmission Plan. This selection of projects
- supports the NorthernGrid system for a 10-year future and is less expensive to build than the entire set
- of projects that comprise the BLMP. The Cedar Hill route conservatively increases the capacity of the
- transmission system by 1500 MW. None of the interregional or non-incumbent regional projects
- resulted in as few violations as regional combination {03} and while there is merit in considering the
- 449 construction of regional combination {03} along with interregional or non-incumbent regional projects,
- the costs would be significantly higher than constructing just regional combination {03} and the
- reliability results suggest that regional combination {03} results in a system that is as or more reliable.
- 452

442

453 Appendix A: Definitions and Terms

454 Attachment K from NorthWestern Energy is provided here for reference to the process or definitions.



Accepted, effective April I, 2020, NorthWestern Corp., 170 FERC ¶ 61,298 (Mar. 31, 2020)

> NorthWestern Corporation Montana OATT

ATTACHMENT K

Transmission Planning Process







Final Study Scope for the 2020- 2021 NorthernGrid Planning Cycle

Member Planning Committee Approval Date: September 30, 2020





459 Appendix C: Rankings

460 Table 3: Voltage Class for Ranking

From	•	То	•	Rank	-
0	٧٧	50	kV		0.1
50 l	٧٧	100	kV		0.1
100	٧٧	200	kV		0.3
200	٧٧	300	kV		0.5
300	٧٧	400	kV		0.8
400 l	٧	1000	kV		1

461

462

463 Table 4: NERC TPL Category for Ranking

P01All lines in serviceP10.5N-1P20.1Multiple outagesP30.075N-1-1P40.1Multiple outagesP50.1Multiple outagesP60.075N-1-1P70.1Multiple outages	Category	Rank	Description
P10.5N-1P20.1Multiple outagesP30.075N-1-1P40.1Multiple outagesP50.1Multiple outagesP60.075N-1-1P70.1Multiple outages	P0	1	All lines in service
P20.1Multiple outagesP30.075N-1-1P40.1Multiple outagesP50.1Multiple outagesP60.075N-1-1P70.1Multiple outages	P1	0.5	N-1
P30.075N-1-1P40.1Multiple outagesP50.1Multiple outagesP60.075N-1-1P70.1Multiple outages	P2	0.1	Multiple outages
P40.1Multiple outagesP50.1Multiple outagesP60.075N-1-1P70.1Multiple outages	P3	0.075	N-1-1
P50.1Multiple outagesP60.075N-1-1P70.1Multiple outages	P4	0.1	Multiple outages
P6 0.075 N-1-1	P5	0.1	Multiple outages
D7 0.1 Multiple outages	P6	0.075	N-1-1
P7 0.1 Multiple Outages	P7	0.1	Multiple outages



465 Table 5: Violations for Ranking

	LV_Type	•	Rank	Ψ.	Description	-
	Interface MW		(0.5	Mild overload of path rating.	
	Interface MW			1	Heavy overload of path - potential stability problems.	
	Branch Amp		(0.5	Mild overload of line.	
	Branch Amp			1	Heavy overload of line. Possibility of automated tripping.	
	Branch MVA		(0.5	Mild overload.	
	Branch MVA			1	Heavy overload.	
	Unsolved			1		
	Bus High Volts		(0.5		
	Bus High Volts			1		
	Bus Low Volts		(0.5		
	Bus Low Volts			1		
	Change Bus Low Volts		(0.5		
	Change Bus Low Volts			1		
	Change Bus High Volts		(0.5		
466	Change Bus High Volts			1		
469 470	event is:					by u
471					(1) * (0.5) * (0.5) = 0.25	
472						
473						
474	Appendix D: Complete list of all RC combos					
475	Table 6: Working version of the Regional Combinations Table					
476	***Placeholder for Regional Combinations Table***					
		-				



478 Appendix E: Visual Aides for the Regional Combinations



NorthernGrid

- -











492 2nd best group of performers – RC 10-12 – no B2H

