## NorthernGrid

Interregional Coordination Meeting March 30, 2021

#### Topics

Introduction to NorthernGrid

Submitted Data

**Study Scope** 


**Power Flow Cases** 

WECC Anchor Data Set Actions



## Association of Members





#### Committees

#### Member

Enrolled Party and States


Member Planning Enrolled Parties Planning

Cost Allocation Task Force




#### **Enrolled Parties**

 Members who file a Regional Transmission
Planning Tariff with FERC



#### **Regional Transmission Process**

• Work together to create a Regional Plan that "exceeds" a simple rollup of all the Local Area Plans



#### A Regional Transmission Plan is <u>not</u> a Construction Plan

NorthernGrid

#### Data Submission Process

- NorthernGrid Utility Data
  - Local Plans
  - Load Forecast
  - Resource Forecasts
  - Public Policy Requirements
- Non-Incumbent and Merchant Project Data
  - Associated Resources


#### Gather Data

#### • Prior regional plan

- Local plans
- WECC cases
- Other assumptions and data
- Inter Regional Transmission (ITP) projects
- Projects requesting FERC cost allocation
- Alternative Projects
- Non-incumbent and Merchant Projects




## Develop Study Scope






## FERC Filing Lessons Learned





## Execute the Study Scope






#### NorthernGrid Schedule of Deliverables





NorthernGrid

## NorthernGrid Subregions


- Pacific Northwest
- Intermountain













#### **NorthernGrid**

CO


NM


#### Resource Retirements






## Resource Additions






## Regional Transmission Additions



#### Power Flow Case Development






#### Unpacking the Power Flow Base Cases







1) Heavy Summer Load July 30<sup>th</sup> Hour ending 16:00




2) Heavy Winter Load December 19<sup>th</sup> Hour ending 12:00




3) High Wyoming Wind Generation Output February 1<sup>st</sup> Hour ending 1:00




4) High Northwest to Idaho Transfer July 20th Hour ending 17:00




5) High Transfer Across Idaho September 29<sup>th</sup> Hour ending 1:00




## 6) High California to Northwest Transfer March 10<sup>th</sup> Hour ending 15:00



## 7) High West of Cascades Transfer April 3<sup>rd</sup> Hour ending 11:00




8) High Northwest Hydro June 4<sup>th</sup> Hour ending 18:00




#### Interregional Projects

#### Regional Non-Incumbent and Interregional Projects

2020 - 2030





#### **Regional Combinations**

Modeled Projects	B2H [H]	Gateway West (Pop - Ced- Hem) [E]	Gateway West (Pop - Bor - Mid - Hem) [E]	Gateway West (Mid - Ced)	Gateway West (Ant - Pop) [D.3]	Antelope	Gateway South [F]	SWIP-N	Cross-Tie	TransWest Express DC	TransWest Express DC/AC	Loco Falls Greenline	Cascade Renewable Transmission	Case Stressed Conditions
BLMP**	* X	Х	Х	Х	Х	Х	х							A
RC17		Х			Х	Х	Х	Х						CDE
RC18	Х	Х			Х	Х		Х						CDE
RC19	Х					Х	Х	Х						CDE
RC20	Х	Х				Х	Х	Х						CDE
RC21	Х				Х	Х	Х	Х						CDE
RC22						Х			Х					ABCDEF
RC23		Х			Х	Х	Х		Х					CDE
RC24	Х	Х			Х	Х			Х					CDE
RC25	Х					Х	Х		Х					CDE
RC26	Х	Х				Х	Х		Х					CDE
RC27	Х				Х	Х	Х		Х					CDE
RC28						Х				G				ABCDEF
RC29	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	G			TBD	ABCDEF



#### 2032 Anchor Data Set

# **8,760 HOURS** how to get the most out of next year

Version 2



#### Anchor Data Set Actions

- NorthernGrid Submitted 24 PCM to Power Flow Modeling Issues
- WECC Appointed Bhavana Katyal, 2032 ADS Project Manager
- Issues List Located at

DISCUSSION ITEMS

https://www.wecc.org/RAC/Pages/Default.aspx#

Туре	Title	Modified <b>T</b>	
×	Addressing Round-Trip Export Hour Issues	2021-03-25	



#### Sample Issues List Items

#### Many groups involved

	PCM to PF Data Quality Issues										
Item	Status Date	Status	Submitted By	Issue	Discussion	Data Issue; Software Solution	Resolution	Responsibility			
14			TR TR	limits of generators Generator capacitities greater	ZZ - as discussed above, there appear to be multiple instances of potential limits between PCM internal and the target powerflow. The most limiting limit should be respected Add L&R resources to PF, making sure that the transformer limits are not exceded for the location.	Data issue – need to coordinate to		PCDS SRS Hitachi-ABB PCDS WECC staff			
					Rules of thumb (all need to be checked with basic power flow) •Do not exceed capacity of POI •0 to 34.5 kV: 5 MW •34.5 to 69 kV: 25 MW •115 kV: 25 to 50 MW •230 kV: 50 to 125 MW •500 kV: 250 to 1250 MW						

**Some Recommended Solutions** 



## Thank you!



