


The background of the slide features a blue gradient with a series of white, thick, diagonal lines that intersect to form a grid-like pattern, resembling a stylized transmission grid.

NorthernGrid


Draft Final Regional Transmission Plan
Public Review

Planning Requirement

- Draft Final Transmission Plan posted on 9/30/21



From the Draft to the Draft Final



Setting the stage



WALK-THROUGH OF REPORT



HIGHLIGHT MAJOR CHANGES FROM THE
DRAFT REGIONAL TRANSMISSION PLAN



NorthernGrid

General Corrections



References to “OATT” either removed or spelled out



Plan selected on efficiency (rather than cost-effective)



Appendices updated or created



Appendix references cleaned up




500 kV updated throughout



Cover Page


Draft

Draft Final



NorthernGrid

New Page Added: Acknowledgements

		Draft 2020- 2021 Regional Transmission Plan
23	Acknowledgements:	
24	NorthernGrid Members & Participants	Consultants and Other Contributors
25	Avista Corporation	Northwest Power Pool
26	Berkshire Hathaway Energy (BHE)	Power Systems Consulting (PSC)
27	Bonneville Power Administration	Old Saw Consulting
28	Chelan County PUD	Harris PCM
29	Grant County PUD	CAISO
30	Idaho Power Company	WestConnect
31	NorthWestern Energy	
32	PacifiCorp	
33	Portland General Electric	
34	Puget Sound Energy	
35	Seattle City Light	
36	Snohomish County PUD	
37	Tacoma Power	
38		
39	Interregional or non-Incumbent Transmission Project Sponsors	
40	Fill in here...	
41		
42	State Commissions etc.	
43	Fill in here...	
44		

Disclaimer Added

65

66

67

68 Disclaimer: The data and analyses contained in this report are not warranted by NorthernGrid or any
69 other party, nor does NorthernGrid accept delegation of responsibility for compliance with any industry
70 compliance or reliability requirement, including any reliability standard. Any reliance on this data or
71 analyses is done so at the user's own risk.

pg. 3

Regional Planning Development

Draft

Draft Final

72	Interregional and Non-Incumbent Regional.....	17
73	Interregional Coordination Process.....	19
74	Cost Allocation	19
75	Regional Transmission Plan	20
76	Appendix A: Definitions and Terms.....	20
77	Appendix B: Study Scope	21
78	Appendix C: Rankings.....	23
79	Appendix D: Complete list of all RC combos.....	24
80	Appendix E: Visual Aides for the Regional Combinations.....	25

Regional Planning Development

The Regional Transmission Plan is the result of the work performed as outlined in the study scope for the NorthernGrid 2020-2021 regional transmission planning process. Regional Planning is required under FERC Orders No. 890 and 1000 and was executed in accordance with each Enrolled Party's Open Access Tariff (OATT) Attachment K – Regional Planning Process and NorthernGrid Planning Agreement. The production of a Regional Transmission Plan satisfies FERC Order 1000 requirements for each region to produce a plan. To develop the Plan, the NorthernGrid members established the Baseline Projects which were then evaluated for inclusion in the final Regional Transmission Plan. NorthernGrid used steady state analysis to assess which projects could best meet system reliability performance requirements and transmission needs for the NorthernGrid footprint in a 10-year future. Enrolled Parties submitted updated Load and Resource information which was incorporated into the study effort. There were no Material Adverse Impacts noted for any of the solutions considered.

NorthernGrid Overview

The NorthernGrid is comprised of Avista (AVA), Bonneville Power Administration (BPA), Chelan PUD (CHPD), Grant County PUD (GCPD), Idaho Power Company (IPC), Berkshire Hathaway Energy (BHE, formerly Montana Alberta Tie Line, MATL), NorthWestern Energy (NWM), PacifiCorp East and West (PACE and PACW), Portland General Electric (PGE), Puget Sound Energy (PSE), Seattle City Light (SCL), Snohomish PUD (SNPD), Tacoma Power (TPWR). The member Balancing Authority Areas are illustrated in Figure 2 below.

4



Draft 2020- 2021 Regional Transmission Plan

Regional Planning Development

The Regional Transmission Plan is the result of the work performed as outlined in the study scope for the NorthernGrid 2020-2021 regional transmission planning process. Regional Planning is required under FERC Orders No. 890 and 1000 and was executed in accordance with each Enrolled Party's Open Access Tariff (OATT) Attachment K – Regional Planning Process and NorthernGrid Planning Agreement. The production of a Regional Transmission Plan satisfies FERC Order 1000 requirements for each region to produce a plan. To develop the Plan, the NorthernGrid members established the Baseline Projects which were then evaluated for inclusion in the final Regional Transmission Plan. NorthernGrid used steady state analysis to assess which projects could best meet system reliability performance requirements and transmission needs for the NorthernGrid footprint in a 10-year future. Enrolled Parties submitted updated Load and Resource information which was incorporated into the study effort. There were no Material Adverse Impacts noted for any of the solutions considered.

The regional planning process is designed to be a "bottom up" approach in that it begins with a compilation of the Members' local area plans which allows the planning emphasis to shift from the local to the regional footprint. The Transmission Providers, in conjunction with participation from stakeholders, public service commissioners, and interested parties have developed local area plans that meet the regulatory requirements for their respective areas. The projects that have been identified in the local area planning process are assumed to be in service for the regional planning effort.

This regional planning process is intended to focus on those projects that are of "regional significance". "Regional significance" is not a defined term in either the Members Planning Agreement or the OATT; rather, it is used to describe those projects whose presence, or lack thereof, would influence the overall reliability of the NorthernGrid footprint. A local project may improve the ability to serve native load or decrease the number of unplanned outages for a specified subsystem but typically is not going to influence larger transmission paths. A project that is more regional in nature may both increase the ability to serve native load as well as influence a larger transmission path.

NorthernGrid Overview

The NorthernGrid is composed of Avista (AVA), Bonneville Power Administration (BPA), Chelan PUD (CHPD), Grant County PUD (GCPD), Idaho Power Company (IPC), BHE U.S. Transmission as the owner of the Montana Alberta Tie Line (MATL), NorthWestern Energy (NWM), PacifiCorp East and West (PACE and PACW), Portland General Electric (PGE), Puget Sound Energy (PSE), Seattle City Light (SCL), Snohomish PUD (SNPD), Tacoma Power (TPWR). The member Balancing Authority Areas are illustrated in Figure 2 below.

About the process

Local versus Regional

The geographic boundary

Draft

Draft Final

NorthernGrid

Draft 2020- 2021 Regional Transmission Plan




Figure 2: NorthernGrid footprint

Figure 2 shows the NorthernGrid footprint. For the purposes of the regional transmission plan data analysis and study case development, the NorthernGrid MPC divided the study area into the Pacific Northwest (NG-PNW) and Intermountain states (NG-IM) areas as shown by the brown line in Figure 2 above.

Study Process

Study Scope

The objective of the transmission planning study is to produce the NorthernGrid Regional Transmission

NorthernGrid

Draft 2020- 2021 Regional Transmission Plan




Figure 2: NorthernGrid footprint

Figure 2 shows the NorthernGrid footprint. For the purposes of the regional transmission plan data analysis and study case development, the NorthernGrid MPC divided the study area into the Pacific Northwest (NG-PNW) and Intermountain states (NG-IM) areas as shown by the brown line in Figure 2 above. The NorthernGrid footprint is a large, geographically diverse region that combines the needs of two previously separate regions. Some portions of the region may experience peak loading in the summer whereas other portions may experience peak loading in the winter. The Study Scope was developed to incorporate the ability to keep the region separated, should the results indicate that a separation is indeed useful. During the analysis, it was found that the separation of the NorthernGrid footprint was not needed. The brown line has been kept in this figure to help maintain consistency with the Study Scope and will not be specifically referenced hereafter.

Introduces language to explain geographic boundary

New Section: Planning Development

200 Planning Development

201 The intent of FERC 1000 is to improve the regional planning process and identify opportunities for any
202 transmission developer, incumbent or non-incumbent, to coordinate and develop solutions that are
203 both beneficial to the developer as well as the region to which that developer interconnects. Given
204 proper coordination and communication, only the necessary facilities would get identified, and those
205 facilities become the RTP. The RTP is not a construction plan and the Members have no obligation to
206 build the facilities identified in the RTP.

207 A few notables about the planning process: amongst other things, transmission needs are driven by
208 reliability and by integrated resource planning. Reliability planning is driven by North American
209 Reliability Council (NERC) criteria which provides utilities with a consistent methodology to identify
210 facilities needed to support reliability. Integrated resource planning is driven by the market and
211 resources are identified by the specific utility that is looking to build future generation. The member
212 utilities combine the transmission needs driven by reliability with the transmission needs driven by the

pg. 8



Draft 2020- 2021 Regional Transmission Plan

213 market to develop their overall transmission needs in the form of the Loads and Resources data
214 submittal to the Western Electric Coordinating Council (WECC); that data gets consolidated and is the
215 basis for building base cases. Member utilities are also tasked with ensuring that all public policies are
216 reflected in their transmission needs. Public policies that initiate at the beginning of a planning cycle or
217 make a shift during the planning cycle may not necessarily get reflected in the regional planning process.
218 Member utilities need to decide how they are going to implement the changes to the transmission
219 system that will result from a change to public policy and those decisions take some time to make.
220 Similarly, not all generation or transmission projects driven by public policy changes can be reflected in a
221 long-term planning study. While this RTP may not reflect the changes driven by public policy in this
222 cycle, the process is such that there is the opportunity for those changes to get captured in the next
223 planning cycle.

Improving the ADS: new language

Draft

Draft Final

126 any area-specific Member Committee criteria, otherwise, NERC IPL U01-U4 criteria was used.

127 Loads and Resources

128 Members submitted Loads and Resources data along with their current transmission plans in the first
129 quarter; this data was consolidated and used to develop the Study Scope. The needs of the
130 NorthernGrid footprint were identified through these submittals. No Loads and Resources data updates
131 were submitted in the fifth quarter. All loads and resources characteristics are captured in the Study
132 Scope which is available in Appendix B: Study Scope.

133 Base Case Development

134 The WECC 2030 Anchor Data Set seed case was used as the starting point to produce the base cases
135 used in the reliability analysis. The Anchor Data Set seed case was put through a production cost
136 modeling effort to identify the stress conditions of interest for the NorthernGrid footprint from 8760
137 potential hourly conditions. These operating conditions were created through modeling the economic
138 dispatch of the resources combined with the expected loading conditions for the time of year and
139 creating base cases for each of the 8760 hours in a year. These models account for seasonal variations
140 in load and resource availability. For example, base cases representing a spring condition will reflect
141 more availability of hydro generation than do the base cases that represent a fall condition. The
142 NorthernGrid Planning Committee discussed the stress conditions of interest and ultimately selected
143 eight hours to model and study the regional transmission system. These eight hours, representing eight
144 dispatch system conditions, were selected to represent known or expected operating conditions for the
145 NorthernGrid footprint and are identified in Table 1. Members reviewed these cases and provided
146 additional tuning and adjustments as appropriate for each scenario.

147 The hours were selected for known or expected "stresses" on the NorthernGrid footprint. The
148 NorthernGrid footprint spans a wide geographic area; because of this, heavy conditions for both
149 summer and winter were selected. There is enough proposed wind generation in Wyoming to have a
150 potential impact on the reliability of the NorthernGrid footprint; because of this, an hour representing
151 high output from Wyoming wind resources was selected. Needs were also identified across southern
152 Idaho, so a high Idaho to Northwest (west to east) case and Borah West (east to west) case were
153 developed. The NorthernGrid Planning Committee voted on, and approved, the study hours identified in

154 .

155

156

157

158

159

248 Base Case Development

249 The WECC 2030 Anchor Data Set (ADS) seed case was used as the starting point to produce the base
250 cases used in the reliability analysis. The Anchor Data Set seed case was put through a production cost
251 modeling effort to identify the stressed conditions of interest for the NorthernGrid footprint from 8760
252 potential hourly conditions. These operating conditions were created through modeling the economic
253 dispatch of the resources combined with the expected loading conditions for the time of year and for
254 each of the 8760 hours in a year. These models account for seasonal variations in load and resource
255 availability. For example, base cases representing spring conditions will reflect more availability of
256 hydro generation than do the base cases that represent fall conditions. The NorthernGrid Planning
257 Committee discussed the conditions of interest and ultimately selected eight hours to model and study
258 the regional transmission system. These eight hours were selected to represent known or expected
259 operating conditions for the NorthernGrid footprint and are identified in Table 1. Members reviewed
260 these cases and provided additional tuning and adjustments as appropriate for each scenario.

261 In the process of developing and selecting the stressed dispatch conditions, it was found that there are
262 opportunities for improving the ADS. NorthernGrid worked closely with WECC to provide a list of topics
263 where the ADS could be improved and WECC is actively working through those issues. A simple example
264 of where the ADS could be improved is in the weather data that is being used: the data is based on
265 years-old data and does not necessarily reflect current weather data. All topics are provided in
266 Appendix H: Complete list of all ADS opportunities supplied to WECC.

267 The hours were selected for known or expected "stresses" on the NorthernGrid footprint. The
268 NorthernGrid footprint spans a wide geographic area; because of this, heavy conditions for both
269 summer and winter were selected. There is enough proposed wind generation in Wyoming to have a
270 potential impact on the reliability of the NorthernGrid footprint; because of this, an hour representing
271 high output from Wyoming wind resources was selected. Needs were also identified across southern
272 Idaho, so a high Idaho to Northwest (west to east) case and Borah West (east to west) case were
273 developed. The NorthernGrid Planning Committee voted on, and approved, the study hours identified in

274

275

276

277

278 Table 1.

279

280

281

Complete overhaul of Contingencies and Criteria

Draft

169 Contingencies and Criteria

170 Contingency analysis is the modeling of systematically removing specified pieces of equipment from
171 service and measuring the resulting impact to the transmission system. Thermal overloads occur when
172 the electrons flowing through a piece of equipment exceed the capability of the equipment which
173 causes heat to build up; excess heat occurs which can then damage the equipment. Typically, a thermal
174 overload results from the loss of a transmission line or transformer, not necessarily from the loss of
175 voltage control elements such as capacitor or reactor banks. Voltage excursions occur when the
176 reactive support of the transmission system changes, as can happen during the loss of a piece of
177 equipment. Voltage excursions can be high or low, either of which causes undue stress on the
178 equipment experiencing the excursion. Due to the interplay of all the pieces of equipment in a
179 transmission system, the loss of any piece of equipment has the potential to cause a voltage excursion
180 on the transmission system.

181 NorthernGrid Members submitted regionally significant contingencies used in the analysis for the
182 development of the Plan. Contingencies on major WECC Paths relevant to the NorthernGrid footprint as
183 well as contingencies on pieces of equipment in the 200 kV and above voltage classes were the primary
184 focus. These regionally significant contingencies were selected for their criticality to the NorthernGrid
185 footprint. The contingencies were categorized using Table 1 from NERC TPL-001-4. The post-
186 contingency system analysis was performed using applicable NERC and WECC criteria while accounting
187 for any member provided thermal or voltage criteria.

188 The NorthernGrid footprint as well as neighboring regions were monitored during the contingency
189 analysis to determine if any negative impacts occur to the reliability of the transmission system due to
190 the introduction of the regional projects. If negative impacts to the transmission system of neighboring
191 regions could not be mitigated through operational changes for any regional combination, coordination
192 would have to occur to identify the appropriate mitigation and the costs of that mitigation would be
193 added to the cost of the regional project. No negative contingency results were observed in the
194 neighboring regions and as such no Material Adverse Impacts were identified for any of the
195 combinations considered.

196 Selection of Projects

197 The objective of the regional transmission analysis is to identify a set of transmission projects that cost-
198 effectively meets the transmission service and reliability needs of the NorthernGrid footprint ten years
199 in the future. To accomplish this goal, NorthernGrid started with base cases that include member
200 planned future regional projects modeled as "in-service", as displayed below in Figure 4. Collectively,
201 these regional projects comprise the Baseline Member Projects, or the "BLMP". Sensitivity cases based
202 on combinations of various regional project components being systematically removed from the BLMP
203 cases created a set of Regional Combination cases to test against the performance of the BLMP cases.
204 While the BLMP includes the highest number of regional projects, the analysis will evaluate whether a

Draft Final

297 Contingencies and Criteria

298 Contingency analysis is the modeling of systematically removing specified pieces of equipment from
299 service and measuring the resulting impact to the transmission system.

300 Thermal overloads occur when the electrons flowing through a piece of equipment exceed the capability
301 of the equipment which causes heat to build up; excess heat occurs which can then damage the
302 equipment. Typically, a thermal overload results from the loss of a transmission line or transformer, not
303 necessarily from the loss of voltage control elements such as capacitor or reactor banks. Operationally,
304 there are multiple ways to mitigate thermal excursions. For example, remedial action schemes are
305 designed to respond to specific events on the transmission system to help preserve reliability and load
306 service; these actions are programmed and the outcomes to the transmission are expected. Generators
307 may be programmed to reduce their output in response to specific changes on the transmission system.
308 These operational mitigation actions decrease the loading on the overloaded equipment by either
309 reducing the number of electrons altogether or redirecting the electrons to pieces of equipment with
310 larger capabilities. In instances where no pre-planned responses are in place, the transmission system is
311 protected through standard protection devices including relays and breakers. As an example, the pieces
312 of equipment experiencing the thermal overload would be disengaged from service through the actions
313 of the relays and breakers and subsequently, changes the transmission topology naturally occur. This
314 change in topology redirects the electrons which may or may not lead to further thermal excursions on
315 the transmission system. Changes in transmission topology increase the need for Operator intervention
316 and action as the transmission system is in a new state.

317 Voltage excursions occur when the reactive support of the transmission system changes, as can happen
318 during the loss of a piece of equipment. Voltage excursions can be high or low, either of which causes
319 undue stress on the equipment experiencing the excursion. Due to the interplay of all the pieces of
320 equipment in a transmission system, the loss of any piece of equipment has the potential to cause a
321 voltage excursion on the transmission system. Voltage excursions can be mitigated automatically
322 through switching schemes on capacitor and/or reactor banks. These switching sequences do not add
323 further stress or burden to the transmission system as they reduce the reactive need on the
324 transmission system.

325 NorthernGrid Members submitted regionally significant contingencies used in the analysis for the
326 development of the Plan. Contingencies on major WECC Paths relevant to the NorthernGrid footprint as
327 well as contingencies on pieces of equipment in the 200 kV and above voltage classes were the primary
328 focus. These regionally significant contingencies were selected for their criticality to the NorthernGrid

pg. 12





NorthernGrid

Selection of Projects

Draft


Draft Final



Selection of Projects

New Graphic

New language



353

354 Figure 5: NorthernGrid geographical overlay with all Regional, Interregional, and Non-Incumbent Regional projects displayed

355 Figure 4 and Figure 5 provide a visual demonstration of all of the projects that have been submitted for
 356 consideration in the Regional Transmission Plan. In the top left-hand corner of Figure 4, a table is
 357 displayed to show which projects are included in the BLMP. The blue “stick figure” diagram on the left is
 358 the visual representation of the projects and each segment has a corresponding geographically aligned
 359 element depicted on Figure 5. This figure is not demonstrative of the entire set of upgrades associated
 360 with any main portion of the regional combinations, rather it is intended to help the reader understand
 361 in general the topology of interest. Boardman 500 kV is listed as the terminating point of the Boardman
 362 to Hemingway project to help preserve continuity with the naming convention; in actuality, the project
 363 terminates at Longhorn. Visual Aides for all the combinations can be found in Appendix E.

364 After the contingencies were run, the raw counts of violations were ranked using weighting criteria
 365 developed by the NorthernGrid Member Planning Committee. The rankings give less weight to those
 366 contingency categories that either have system adjustments available, can be addressed locally – such

Analysis Results: re-write of entire section

Draft Draft Final



Draft 2020- 2021 Regional Transmission Plan

316 interconnecting with the AC grid at Big Eddy and Harborton substation. There is no proposed generation
317 resource associated with the transmission line.

318 Loco Falls Greenline

319 Absaroka is proposing a merchant transmission project connecting Great Falls 230 kV substation to the
320 Colstrip 500 kV Transmission System. The project consists of two 230 kV transmission circuits and a new
321 Loco Mountain Substation with 230 to 500 kV transformation. There are no proposed generation
322 resources associated with the transmission line.

323 Analysis Results

324 Once the base cases were created to reflect the topology and loading conditions of interest, they were
325 run through contingency analysis. When running contingency analyses, both the cause of the
326 contingency and the impact of the contingency are vital to ascertaining the reliability of the transmission
327 system. The cause and the impact are considered in conjunction with the voltage class of the
328 equipment. In general, losses of higher voltage equipment have more of an impact on the transmission
329 system than do the losses of lower voltage equipment. Altogether, the ranking factor for each of the
330 three categories: voltage class, cause of the contingency, impact of the contingency was multiplied to
331 produce an overall Ranking, an example is provided in Appendix C: Rankings.

332 Base Cases

Ranked Contingency Results for BLMP base cases



460 Analysis Results


461 Once the base cases were created to reflect the topology and loading conditions of interest, they were
462 run through contingency analysis. When running contingency analyses, both the type of the
463 contingency and the impact of the contingency are vital to ascertaining the reliability of the transmission
464 system. The type and the impact of the contingency are considered in conjunction with the voltage class
465 of the equipment. In general, losses of higher voltage equipment have more of an impact on the
466 transmission system than do the losses of lower voltage equipment. From a NorthernGrid perspective,
467 the contingencies that result in the loss of large amounts of load or the inability to honor transmission
468 arrangements are those that are regionally significant and warrant further scrutiny.

469 Initially, the results were compiled and the total number of violations from each contingency summed
470 together, regardless of the voltage level of the piece of equipment lost, the voltage of the piece of
471 equipment impacted, or the extremity of the event. Appendix C: Rankings shows a figure of the
472 unranked results of the contingency analysis.

473 To help identify regionally significant contingencies, each contingency result was multiplied by ranking
474 factors: voltage class, type of the contingency, and impact of the contingency, to produce an overall
475 Ranking for that contingency. The larger the resulting ranking, the more regionally significant the
476 contingency. Voltage class refers to the kV rating of the equipment: the larger the rating, the larger the
477 ranking factor. Type of the contingency refers to the NERC TPL-001-4 criteria which is the guiding
478 document used to classify all contingencies analyzed. The contingencies in NERC TPL-001-4 contain
479 scenarios that range from outages of single pieces of equipment to severe faults that impact multiple
480 pieces of equipment. It is quite common for a transmission system to have a single piece of equipment
481 out of service, either planned or unplanned, and it is less common for a transmission system to
482 experience fault events that result in the loss of multiple pieces of equipment. Because of this, single
483 outage contingencies were given a larger ranking factor than severe contingencies. The impact of a
484 contingency refers to what happens to the transmission system when a contingency occurs.
485 Contingencies that caused minor violations were given a smaller ranking factor than those that led to
486 major violations. From a NorthernGrid perspective, a minor violation is one that can be readily
487 mitigated operationally with no anticipated damage to equipment. A major violation may cause
488 cascading outages or equipment damage. Each contingency from each base case was ranked per the
489 ranking factors; all contingency results displayed in this report are ranked contingency results. Ranked
490 contingency results have no known unit. An example calculation of ranking a contingency as well as a
491 comparison of the ranked versus the un-ranked results is provided in Appendix C: Rankings.

492 Base Cases

Base Cases: revamp of entire section



493

494

Figure 8: Ranked contingency results for the eight BLMP base cases

495

496

497

498

499

500

501

502

503

504

505

506

507

508

509

510

511

512

513

514

515

516

Figure 8 displays the ranked contingency violations for the eight base cases developed to represent the different stress conditions of interest. All eight base cases are derived from the BLMP and their only differences stem from the varying load and resource combinations that resulted from the production cost model analysis. Thermal excursions identify the portions of the system that may need infrastructure improvement to support the movement of electrons whereas voltage changes identify the portions of the transmission system that may need reactive equipment to support the overall voltage. By emphasizing the change in volts, either high or low, the analysis effort is well situated to identify those contingencies that led to changes in the transmission system and to put less emphasis on voltage excursions that may be present in the BLMP due to the initial conditions of the case selected through the PCM process.

A few observations about the results from the BLMP analysis:


1. It makes sense that there are fewer thermal excursions in the winter case than the rest of the loading conditions. Many entities allow for extra loading on transmission elements in the winter due to the cooling effect of the lower temperatures associated with winter conditions. The cooling effect of the temperature allows for an increase of electrons to transfer without damaging equipment.
2. Northbound flows on the COI resulted in the fewest violations for these 8 cases.
3. The Summer Peak operating condition resulted in a large number of thermal overloads.

The projects in the BLMP have been identified to resolve the reliability concerns and meet the transmission obligations of the entities on an individual level and do not necessarily resolve all the potential operating conditions or stressed conditions that may occur in the larger NorthernGrid footprint.

Regional Combinations

17 Regional Combinations


18 After the initial analysis was performed on the BLMP, the contingency analysis was then extended to
19 looking into different subsets of the BLMP. The Technical Subcommittee of the Member Planning
20 Committee convened to determine the subsets, or regional combinations, of the BLMP to analyze.




21
22 Figure 9: Ranked contingency results, all regional combinations with all cases

Updated Graph
Observations adjusted to correspond

New material in Regional Combinations



561

562  Figure 11: Regional combinations {03, 04, 05}

563 In all regional combinations of interest, the upgrade from Bridger/Anticline to Aelous will not be
564 specifically mentioned as construction is already complete.

565 As can be seen in Figure 11, there are multiple subsets of the BLMP that perform similarly to the BLMP,
566 and further considerations are warranted. The following section provides more discussion and
567 introduces some of the merits and demerits of each of these five regional combinations.

568 Regional combination {03} is a new line that connects Hemingway to Populus via Cedar Hill. Regional
569 combination {03} increases the west-bound capacity from Populus to Hemingway because it adds a new,
570 independent path for electrons to flow. Regional combination {03} also mitigates the limiting
571 contingency; currently, the limiting contingency for megawatts flowing between Populus and
572 Hemingway is a loss on the Hemingway-Midpoint-Borah-Populus line.

573 Regional combination {04} takes regional combination {03} and adds in the Midpoint to Cedar Hill
574 segment. The Midpoint to Cedar Hill segment does not fundamentally improve the reliability results
575 over regional combination {03} as can be seen in the results in Figure 11. The change in reliability results
576 from regional combinations {03} to {04} does not warrant the cost incurred to construct Midpoint to
577 Cedar Hill in this analysis; therefore, regional combination {04} will be removed from further scrutiny.

578 Regional combination {05} rebuilds existing facilities and does not create a new path for electrons to
579 flow. the loss of any of the line segments: Hemingway to Midpoint, Midpoint to Borah, Borah to
580 Populus, could lead to the reduction of west-bound schedules; regional combination {05} does not
581 ameliorate this situation. Regional combination {05}, however, re-builds existing facilities and the

New graphic to help illustrate
the main “contenders”

New language to discuss the
pros and cons of the main
contenders

Interregional and Non-Incumbent Projects (Essentially New)


- New and Improved Graphs
- More language

607 The interregional projects that have been submitted to the NorthernGrid region for consideration in the
608 2020-2021 regional transmission process are designed to take the output from renewable generation
609 and deliver it to a load in a neighboring region.

610 Three interregional and two non-incumbent regional projects were incorporated and analyzed to
611 determine if either alone or in conjunction with the leading regional combinations, they would create a
612 more cost-effective or efficient NorthernGrid transmission system.

613 The first stage of the analysis was designed to ascertain if the interregional or non-incumbent regional
614 project would meet the needs of the NorthernGrid region alone, without the presence of the other
615 planned projects. The second stage of the interregional and non-incumbent regional analysis was to
616 determine if there was any benefit in adding the interregional or non-incumbent regional project to
617 subsets of the BLMP. The third phase of the interregional and non-incumbent regional analysis allowed
618 for increased flows on the interregional or non-incumbent projects and the opportunity to determine if
619 the interregional or non-incumbent project with megawatts flowing on them was better for the
620 NorthernGrid footprint than just the projects alone.

621 Figure 13 below shows the ranked contingency results for the first stage of the interregional and non-
622 incumbent regional analysis. Each interregional or non-incumbent regional project was first modeled
623 alone with no regional upgrades.



624
625 Figure 13: Each interregional or non-incumbent regional project with no regional upgrades

626 Each interregional or non-incumbent regional project alone results in significantly more ranked
627 contingency violations than the BLMP.

628 The second stage of the analysis explored the interaction of the interregional and non-incumbent
629 projects with various regional projects.

630

631



Thank you!

