

NorthernGrid

Enrolled Parties and States Committee

July 10, 2025

EPSC Agenda July 10, 2025



Review the Timeline for Rollout

Highlight opportunities for this group to engage



Technical Update


Base Case Process
Initial Results



Open Comment



2025 Schedule for rollout of RTP




Study Scope Changes

- [NG Study Scope 2024 2025 Draft V2.docx](#)
- Summary of NorthernGrid Data Submittals for the 2034 future
 - Updated Load Projection
 - Removal of Greenlink West upon confirmation that it is Committed
- Loads Summary
 - Table1: NorthernGrid Loads updated
 - Description of load increase updated



Study Scope Changes

- Updated Graphic



Study Scope Changes

- Member-Driven Transmission Projects
 - Greenlink North description updated
- Base Case Conditions
 - Stressed hour selection updated
- Appendix B
 - Greenlink West removed
- Appendix C
 - Greenlink description updated



Base Case Process

Selection of Stressed Conditions

Creation of power flow from production cost modeling

Incorporation of Regional Combinations

Running of Contingency Analysis

Initial Results



Stressed Conditions

Heavy System Loading, Lower renewable output

North to South, East to West

Low Hydro/End of Summer

East to West


West to East

South to North


Summer Peak

Winter Peak


Westbound West of Cascades North



Example: West to East



Creation of power flow from production cost modeling



Export the hour from
Production Cost Model



Run through
transformation process




Fine Tune Power Flow



Incorporation of Regional Combinations

Regional Combination	All Greenlink Projects	MATL	One Nevada #2	Gateway West, Anticline-Populus	Gateway West, Populus-Cedar Hill-Midpoint	Gateway West, Populus-Borah, Cedar Hill-	Cascade Renewable Transmission System	Clover-Robinson-Cross Tie	Sagebrush	Western Bounty	Blueprint	Bonanza/John Day to Bonanza	Bethel Round Butte (Lambert Mountain View)
1													
2	x	x	x	x	x	x					x	x	x
3	x	x	x	x	x	x	x	x			x	x	x
4	x	x	x	x	x	x	x	x	x	x	x	x	x
5							x						
6								x					
7	x		x					x					
8	x		x					x	x	x			
9	x		x										
10	x												
11	x							x					
12				x	x								
13				x	x	x							
14				x									
15				x	x	x				x			
16	x		x	x	x	x							
17	x	x	x	x	x	x		x					
18	x	x	x	x	x	x	x						x
19								x					x
20	x	x	x	x	x	x					x		
21	x	x	x	x	x	x						x	
22	x	x	x	x	x	x							x

RC 4:
“Bugatti Case” All Projects modeled as In-Service



Running of Contingency Analysis



Two Servers



So Many
Cores



22ish hour
runtime



Ranking

Voltage Level of Results,
measured at higher kV side

From	To	Rank
0 kV	50 kV	0
50 kV	100 kV	0
100 kV	200 kV	0.5
200 kV	300 kV	1
300 kV	400 kV	1
400 kV	1000 kV	1

Type of Contingency

Category	Rank	Description
P0	1	All lines in service
P1	0.8	N-1
P2	0.5	Multiple outages
P4	0.3	Multiple outages
P5	0.3	Multiple outages
P7	0.8	Multiple outages
P3	0.1	N-1-1
P6	0.1	N-1-1
unknown	0.5	

Levels of impact

LV_Type	From	To	Rank	Description
Interface MW	0%	10%	0	Mild overload of path rating.
Interface MW	10%	99999999999999%	0	Heavy overload of path - potential stability problems.
Branch Amp	0%	15%	1	Mild overload of line.
Branch Amp	15%	99999999999999%	1.5	Heavy overload of line. Possibility of automated tripping.
Branch MVA	0%	15%	1	Mild overload.
Branch MVA	15%	99999999999999%	1.5	Heavy overload.
Unsolved	0%	99999999999999%	1	
Bus High Volts	0%	10%	1	
Bus High Volts	10%	99999999999999%	1.5	
Bus Low Volts	0%	10%	1	
Bus Low Volts	10%	99999999999999%	1.5	
Change Bus Low Volts	0%	10%	1	
Change Bus Low Volts	10%	99999999999999%	1.5	
Change Bus High Volts	0%	10%	1	
Change Bus High Volts	10%	99999999999999%	1.5	
WECC TPL CRT WR1.1.2	0%	99999999999999%	1	




Ranking results
for Thermal
Overloads and
Unsolved
Contingencies,
NorthernGrid
footprint

**There are no
unsolved
contingencies



Sorted NorthernGrid footprint Rankings



Count of
Thermal
overloads for
200+ kV
equipment for
NorthernGrid
footprint


	Fal_E W	Spr_S N	Spr_W E	Sum_HLoa d	Sum_LHydr o	Sum_WOC N	Win_HLoa d	Win_HLoad_LRe n	Win_NS_E W
RC01	64	49	28	128	88	60	82	91	70
RC02	64	52	30	127	85	59	80	90	55
RC03	64	51	27	141	89	61	85	93	58
RC04	70	51	28	105	93	60	95	93	59
RC05	62	47	28	129	90	51	79	96	70
RC06	68	46	25	130	90	61	84	94	72
RC07	68	45	28	121	91	63	88	94	74
RC08	68	48	26	111	94	64	87	98	73
RC09	64	50	30	130	89	62	85	95	74
RC10	70	49	28	128	87	61	80	91	70
RC11	67	43	25	126	88	62	81	92	70
RC12	69	57	27	133	88	60	84	92	59
RC13	66	57	27	131	88	58	83	92	58
RC14	63	42	28	132	86	62	82	88	59
RC15	66	59	27	137	89	57	94	102	59
RC16	69	61	29	133	92	59	86	91	59
RC17	64	50	28	136	91	63	92	96	67
RC18	70	48	32	133	90	60	77	93	57
RC19	72	39	25	134	86	64	82	88	62
RC20	62	57	38	133	93	63	91	94	62
RC21	66	54	30	136	91	59	83	94	62
RC22	71	49	32	127	86	62	76	88	57



3 Case examples: Maximum contingency loading for NorthernGrid footprint

	Fal_EW		Spr_SN		Spr_WE	
	Count	Max	Count	Max	Count	Max
RC01	64	13.0%	49	21.7%	28	51.9%
RC02	64	12.8%	52	14.2%	30	51.8%
RC03	64	12.8%	51	14.5%	27	51.8%
RC04	70	12.8%	51	14.6%	28	51.8%
RC05	62	13.0%	47	21.8%	28	51.8%
RC06	68	13.0%	46	21.4%	25	51.9%
RC07	68	13.1%	45	22.3%	28	51.9%
RC08	68	13.5%	48	22.4%	26	51.9%
RC09	64	13.0%	50	22.4%	30	51.9%
RC10	70	13.7%	49	22.0%	28	51.9%
RC11	67	13.7%	43	21.7%	25	51.9%
RC12	69	13.7%	57	14.3%	27	51.9%
RC13	66	13.6%	57	13.8%	27	51.9%
RC14	63	13.0%	42	16.1%	28	51.9%
RC15	66	13.2%	59	13.9%	27	51.9%
RC16	69	13.6%	61	14.3%	29	51.9%
RC17	64	13.7%	50	14.0%	28	51.9%
RC18	70	12.8%	48	13.8%	32	51.8%
RC19	72	13.7%	39	16.3%	25	51.9%
RC20	62	12.8%	57	14.0%	38	51.9%
RC21	66	12.9%	54	13.9%	30	51.9%
RC22	71	12.8%	49	13.8%	32	51.8%





Sum of Rank




Regional Combination	RC01	RC02	RC03	RC04	RC05	RC06	RC07	RC08	RC09	RC10	RC11	RC12	RC13	RC14	RC15	RC16	RC17	RC18	RC19	RC20	RC21	RC22
Greenlink North		X	X	X			X	X	X	X	X					X	X	X	X	X	X	X
MATL		X	X	X													X	X		X	X	X
One Nevada #2		X	X	X			X	X	X							X	X	X		X	X	X
Gateway West, Anticline-Populus		X	X	X								X	X	X	X	X	X	X	X	X	X	X
Gateway West, Populus-Cedar Hill-Midpoint-Hemingway		X	X	X								X	X		X	X	X	X		X	X	X
Gateway West, Populus- Borah-Midpoint, Cedar Hill-Hemingway		X	X	X									X		X	X	X	X		X	X	X
Cascade Renewable Transmission System			X	X	X													X				
Clover-Robinson (Cross-Tie)			X	X		X	X	X			X						X		X			
Sagebrush (Interregional)				X				X														
Western Bounty (Interregional)				X				X						X								
Blueprint		X	X	X																X		
Bonanza/John Day to Bonanza		X	X	X																	X	
Bethel Round Butte (Lambert Mountain View)		X	X	X														X				X
Robinson Phase Shifter			X	X		X	X	X			X						X		X			
One Nevada #1 Series Comp			X	X		X	X	X			X						X		X			



	Fal_EW-RC12		Fal_EW-RC13		Spr_SN-RC12		Spr_SN-RC13		Sum_LHydro-RC12		Sum_LHydro-RC13	
	Count	Max	Count	Max	Count	Max	Count	Max	Count	Max	Count	Max
Branch MVA	<div></div>	7 13.0%	<div></div>	1 13.0%	<div></div>	7 84.1%	<div></div>	7 84.0%	<div></div>	9 71.8%	<div></div>	9 71.3%
Branch Amp												
P1					<div></div>	16 42.4%	<div></div>	16 40.6%	<div></div>	20 40.9%	<div></div>	20 40.5%
P2	<div></div>	7 40.0%	<div></div>	3 40.0%	<div></div>	8 31.1%	<div></div>	8 31.1%	<div></div>	3 20.6%	<div></div>	3 20.4%
P7									<div></div>	3 32.6%	<div></div>	3 32.7%
unknown	<div></div>	3 3.3%	<div></div>	3 3.3%	<div></div>	9 24.8%	<div></div>	10 25.1%	<div></div>	4 12.6%	<div></div>	4 12.9%



2024-2025 Draft RTP



Open Comment



Thank you!!

Nwpp_northerngrid_staff@westernpowerpool.org



NorthernGrid